

THE REGIONAL MUNICIPALITY OF NIAGARA

TENDER 2017-T-104 (RN 17-04)

**Regional Municipality of Niagara
South Side Low Lift Sewage Pumping Station Upgrades
City of Niagara Falls**

ADDENDUM NO. (7)

I DIRECTIVE

This addendum shall form an integral part of the plans and specifications for the above project and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements of the previously issued drawings and specifications with which it may prove to be at variance, unless otherwise clarified by the Engineer.

This addendum must be signed by the Tenderer in the appropriate space and must be attached to the back of the Form of Tender and placed in the Envelope for submission at the time of tendering. **Tenders not including this addendum signed as requested shall be rejected as informal.**

II REVISION

Please note that the bidding period has been extended until 2:00 pm local time on TUESDAY APRIL 25, 2017.

Question period closed and will not be extended.

1. Division 1, Specification Section 01645 – Clause 1.3 Owner Furnished Productions

On page 5 of 10 **REMOVE:** Clause 1.3.7 Electrical Equipment

ADD: 1.3.7 Electrical Equipment

- .1 Scope of Supply:
 - a) One (1) Automatic Transfer Switch (ATS)
 - b) Four (4) Variable Frequency Drives (VFD)
 - c) Motor Control Centre (MCC) as outlined on the Contract Drawings and Specifications
 - d) four (4) Hubbell Disconnect - (4 X EXB-NFD-2003P)
 - e) four (4) Hubbell Receptacles (4 X HBL460R5W)
 - f) six (6) Eaton Disconnects (1 X 12HD361NF / 4 X 4HD361NF / 1 X 4HD3661NF)
 - g) Lithonia Lighting Package (4 X TYPE A)

- h) Emegilite Emergency Package (1 X EXIT / 1 X BATTERY UNIT)
 - i) K-Tek Engineering Services (Short Circuit Protection Study)
 - j) All associated spare parts and special maintenance equipment.
 - k) On Site services including supervision of installation, start-up, testing and commissioning.
 - l) Preparation and submittal of Pre-purchased equipment drawings and Equipment Installation, Operation and Maintenance Manuals.
 - m) Refer to Division 16, Section 16010, 16014, 16140, 16260, 16480, 16510, 16520 & 16627 for detailed scope of supply.
- .2 Contract Awarded to:
- a) Westburne
 - b) Contact: Ben Veiledal, 519-894-8425
- .3 Equipment Storage Location: Westburne
- .4 Point of delivery: South Side Low Lift Sewage Pump Station
- .5 Date of arrival:
- a) The ATS, Hubbell disconnects, Lithonia lighting package and Emegilite emergency package is on site and being stored temporarily by the Owner.
 - b) Remainder of electrical equipment delivery covered in this section is to be coordinated by Contractor.
- .6 Special handling or storage instructions: Refer to the instructions from the Pre-purchased Vendor.
- .7 Approximate Contract value: \$285,000.

END OF ADDENDUM NO. 7

NO. OF PAGES: 3

Date Issued: April 19, 2017

Signature: Vicki Lafford-Field
Purchasing Agent

THE TENDERER SHALL ADJUST HIS BID PRICE ACCORDING TO THE CHANGES SPECIFIED IN THIS ADDENDUM.

Name of Company: _____

Tenderer's Signature: _____

Date: _____